

Charlotte-Mecklenburg Schools Drinking Water Program Phase II - <1990 Administrative, Middle School and High School Facilities

Laboratory Analytical Results Summary:

Albemarle Road Middle School

6900 Democracy Road

Charlotte, NC 28212

Sampling Date:	11/15/2018
Number of Consumption Points Sampled:	19
Consumption Points with Values Exceeding NCDEQ DWS:	0
Low Value (µg/L):	<0.41 (Pb - lead); <0.83 (Cu - copper)
High Value (µg/L):	2.53 (Pb - lead); 49.3 (Cu - copper)

Notes:

Pb = Lead

Cu = Copper

NCDEQ = North Carolina Department of Environmental Quality

DWS = Drinking Water Standard (Pb = 15 µg/L, Cu = 1,300 µg/L)

µg/L = micrograms per liter or parts per billion (ppb)

Bolded, highlighted values indicate concentrations in excess of the respective NCDEQ DWS

* A detailed report summarizing all assessment and remediation activities will be provided upon completion of the Drinking Water Program Phase II