

Charlotte-Mecklenburg Schools Drinking Water Program Phase II – <1990 Administrative, Middle School and High School Facilities

Laboratory Analytical Results Summary:

Harding University HS

2001 Alleghany Street
Charlotte, NC 28208

Sampling Date:	10/23/2018
Number of Consumption Points Sampled:	61
Consumption Points with Values Exceeding NCDEQ DWS:	1 (Pb)
Low Value (µg/L):	<0.40 (Pb - lead); <0.28 (Cu - copper)
High Value (µg/L):	53.9 (Pb - lead); 431 (Cu - copper)

Consumption Point(s) in Exceedance of NCDEQ DWS							
Sample Collection Point ID	Sample Collection Date	Fixture Type	Location	Initial Result (µg/L)	Flush Result (µg/L)	CMS Notification Date	Corrective Action
405-KS-9	10/23/18	Concession Stand Sink	Football Field Visitor's Concession Stand	53.9 (Pb)	2.07 (Pb)	11/19/18 (Monday)	Fixture taken out of service 11/19/18 (Monday)

Notes:

Pb = Lead

Cu = Copper

NCDEQ = North Carolina Department of Environmental Quality

DWS = Drinking Water Standard (Pb = 15 µg/L, Cu = 1,300 µg/L)

µg/L = micrograms per liter or parts per billion (ppb)

Bolded, highlighted values indicate concentrations in excess of the respective NCDEQ DWS

* A detailed report summarizing all assessment and remediation activities will be provided upon completion of the Drinking Water Program Phase II



Sample Collection Point ID	405-KS-9	Sample Collection Date	10/23/2018
School	Harding University HS		
Fixture Type	Concession Stand Sink		
Notes	Football Field Visitor's Concession Stand		