

## Charlotte-Mecklenburg Schools Drinking Water Program Phase II - <1990 Administrative, Middle School and High School Facilities

### Laboratory Analytical Results Summary:

#### Piedmont Open Middle School

1241 East 10th Street

Charlotte, NC 28204

<b>Sampling Date:</b>	9/25/2018
<b>Number of Consumption Points Sampled:</b>	33
<b>Consumption Points with Values Exceeding NCDEQ DWS:</b>	0
<b>Low Value (µg/L):</b>	<0.40 (Pb - lead); <0.28 (Cu - copper)
<b>High Value (µg/L):</b>	11.1 (Pb - lead); 297 (Cu - copper)

**Notes:**

Pb = Lead

Cu = Copper

NCDEQ = North Carolina Department of Environmental Quality

DWS = Drinking Water Standard (Pb = 15 µg/L, Cu = 1,300 µg/L)

µg/L = micrograms per liter or parts per billion (ppb)

**Bolded, highlighted** values indicate concentrations in excess of the respective NCDEQ DWS

\* A detailed report summarizing all assessment and remediation activities will be provided upon completion of the Drinking Water Program Phase II