

## Charlotte-Mecklenburg Schools Drinking Water Program Phase II - <1990 Administrative, Middle School and High School Facilities

### Laboratory Analytical Results Summary:

#### West Charlotte HS

2219 Senior Drive

Charlotte, NC 28216

<b>Sampling Date:</b>	10/9/2018
<b>Number of Consumption Points Sampled:</b>	68
<b>Consumption Points with Values Exceeding NCDEQ DWS:</b>	1 (Pb)
<b>Low Value (µg/L):</b>	<0.40 (Pb - lead); <0.28 (Cu - copper)
<b>High Value (µg/L):</b>	<b>37.4 (Pb - lead)</b> ; 1,250 (Cu - copper)

Consumption Point(s) in Exceedance of NCDEQ DWS						
Sample Collection Point ID	Sample Collection Date	Fixture Type	Location	Initial Result (µg/L)	Flush Result (µg/L)	Corrective Action
576-KS-9	10/9/2018	Kitchen Sink	Press Box Concession Stand	<b>37.4 (Pb)</b>	8.23	Fixture taken out of service

**Notes:**

Pb = Lead

Cu = Copper

NCDEQ = North Carolina Department of Environmental Quality

DWS = Drinking Water Standard (Pb = 15 µg/L, Cu = 1,300 µg/L)

µg/L = micrograms per liter or parts per billion (ppb)

**Bolded, highlighted** values indicate concentrations in excess of the respective NCDEQ DWS

\* A detailed report summarizing all assessment and remediation activities will be provided upon completion of the Drinking Water Program Phase II



<b>Sample Collection Point ID</b>	576-KS-9	<b>Sample Collection Date</b>	10/9/2018
<b>School</b>	West Charlotte HS		
<b>Fixture Type</b>	Kitchen Sink		
<b>Notes</b>	Press Box Concession Stand		